



## Troubleshooting

These condensation detectors are not likely to become very wet in normal operation, but in the early stages of a project they may be subjected to excessive condensation and become so wet that they take an excessive time to dry out. This can give a false impression that they have a fault that causes them to be permanently giving an alarm signal. If this happens, clean the sensing element with a clean tissue and some isopropyl alcohol. This will cause any water on the sensing element to dry out quickly.

**Alphaglen Laboratories Limited**

Unit 13, Millbrook Business Park, Jarvis Brook, Crowborough, East Sussex TN6 3JZ, United Kingdom

Tel: 01892 664224

Email: [info@alphaglen.co.uk](mailto:info@alphaglen.co.uk)Web: [www.alphaglen.co.uk](http://www.alphaglen.co.uk)